



Ref. Certif. No.

DK-90351-M1-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	LED Luminaire
Name and address of the applicant	NERI SPA SS EMILIA 1622 LONGIANO, FC, 47020 ITALY
Name and address of the manufacturer	NERI SPA SS EMILIA 1622 LONGIANO, FC, 47020 ITALY
Name and address of the factory	NERI SPA VIA DELLE QUERCE 4 LONGIANO, FC, 47020 ITALY <input type="checkbox"/> Additional Information on page 2
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	220-240 V ~ 50/60 Hz 60 W Class II IP66-67 IK09 ta 55°C
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	CTF Stage 2
Model / Type Ref.	RNC20L263I402 – N <input checked="" type="checkbox"/> Additional Information on page 2
Additional information (if necessary may also be reported on page 2)	The report was revised to include technical modifications. <input checked="" type="checkbox"/> Additional Information on page 3
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014, IEC 60598-1:2014/AMD1:2017, IEC 60598-2-1:1979, IEC 60598-2-1:1979/AMD1:1987
As shown in the Test Report Ref. No. which forms part of this Certificate	4788712719-2 issued on 2021-08-03

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2021-08-31
Original Issue Date: 2019-11-29

Signature: Jan-Erik Storgaard



Ref. Certif. No.

DK-90351-M1-UL

Model Details:

Variants

The main model:

All models are rated 220V-240V~ 50/60Hz ta 55°C IP66-67 IK09

The main model RNC20L263I402 - N extends also the model series of RNC20 identified with the following speaking codes: RNC20sooxyzz[aaa] – i where:

“s” – specifies LED module screen finishing (*)

“oo” – specifies optical distribution (*)

“x” – specifies the correlated colour temperature of the source; limited up to 4000K

“yy” – luminous flux output, correlated to LED module and LED driver as follow:

- IA = 1500lm; provided with LECCE 16 LED module and 40W LED driver;
- I0 = 2500lm; provided with LECCE 16 LED module and 40W LED driver;
- I1 = 3500lm; provided with LECCE 16 LED module and 40W LED driver;
- I2 = 4500lm; provided with LECCE LED module and 40W LED driver;
- I3 = 6000lm; provided with LECCE LED module and 75W LED driver;
- I4 = 7500lm; provided with LECCE LED module and 75W LED driver

“zz” – specifies which energy saving driver functions are active (*)

“[aaa]” optionally used to specify customer related options like colour (*)

“i” specifies the type of installation:

- “A” for independent installation or for installation recessed into structures or luminaire bodies with a volume not less than $5,8 \times 10^{-3} \text{ m}^3$ (5,8 litres)
- “N” for independent installation or for installation recessed into Neri’s luminaire bodies of:
 - Square luminaires series 800, 801, 804;
 - Hexagonal luminaires series 700, 701;
 - Round luminaires series 400, 500, 600, 104, 106;
 - Lampara or “egg” shape luminaires series from 210 to 213, from 220 to 223, from 310 to 313, from 320 to 323;
 - Morfomatic Luminaires series from 230 to 233, from 240 to 243, from 330 to 333, from 340 to 343, from 350 to 353, from 370 to 373.

(*) parameters not affecting safety (Each model may also have other variants which are internally identified, related to customers features and not affecting safety).

Additional information (if necessary)



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2021-08-31

Original Issue Date: 2019-11-29

Signature:

Jan-Erik Storgaard



Ref. Certif. No.

DK-90351-M1-UL

Additional Information:

Additionally evaluated to: EN 60598-1:2015, EN 60598-1:2015/A1:2018, EN 60598-2-1:1989
National differences specified in the CB Test Report.

The original report was modified to include the following changes/additions:

- Addition of alternate LED Controlgear;
- Updating of Annexes;
- Updating of photo documentation;

Additional information (if necessary)



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2021-08-31
Original Issue Date: 2019-11-29

Signature:

Jan-Erik Storgaard